

# Certificate



Certificate no.

US 82150004 01

**License Holder:**

Vikram Solar Pvt. Ltd.  
Tobacco House  
1 Old Court House Corner  
700001 Kolkata, West Bengal  
India

**Manufacturing Plant:**

Vikram Solar Pvt. Ltd.  
Falta Sez, Sector - II  
24 Parganas (S)  
743 504 West Bengal  
India

Test report no.: USA-BL 31540003 001

Client Reference: Manoranjan Khuntia

Tested to: UL 1703:2002 R5.14

**Certified Product:** Photovoltaic Module

**License Fee - Units**

**Model Designation:**

ELDORA VSP.72.AAA.03, ELDORA VSPB.72.AAA.03	(275-335 Wp)	7
ELDORA VSP.60.AAA.03, ELDORA VSPB.60.AAA.03	(225-275 Wp)	
ELDORA VSP.54.AAA.03, ELDORA VSPB.54.AAA.03	(205-250 Wp)	
ELDORA VSP.48.AAA.03, ELDORA VSPB.48.AAA.03	(180-220 Wp)	
ELDORA VSP.36.AAA.03, ELDORA VSPB.36.AAA.03	(135-165 Wp)	

All models listed above have 6" Multicrystalline cells.

Maximum System Voltage: 1000 VDC

Fire Safety Class: Type 1

Electrical ratings are provided at Standard Test Conditions (STC) 1000W/m<sup>2</sup>, AM1.5 spectrum, 25°C cell temperature.

Measured values at STC are within +/- 10% of ratings.

Appendix: 1, 1-9

7

**Licensed Test mark:**



**Date of Issue**  
(day/mo/yr)

11/03/2015

# Certificate



Certificate no.

US 82150004 02

**License Holder:**

Vikram Solar Pvt. Ltd.  
Tobacco House  
1 Old Court House Corner  
700001 Kolkata, West Bengal  
India

**Manufacturing Plant:**

Vikram Solar Pvt. Ltd.  
Falta Sez, Sector - II  
24 Parganas (S)  
743 504 West Bengal  
India

Test report no.: USA-BL 31540003 002

Client Reference: Manoranjan Khuntia

Tested to: UL 1703:2002 R5.14

**Certified Product:** Photovoltaic Module

**License Fee - Units**

**Model Designation:**

ELDORA VSP.72.AAA.04, ELDORA VSPB.72.AAA.04	(295-355 Wp)	7
ELDORA VSP.60.AAA.04, ELDORA VSPB.60.AAA.04	(245-295 Wp)	
ELDORA VSP.54.AAA.04, ELDORA VSPB.54.AAA.04	(220-265 Wp)	
ELDORA VSP.48.AAA.04, ELDORA VSPB.48.AAA.04	(195-235 Wp)	
ELDORA VSP.36.AAA.04, ELDORA VSPB.36.AAA.04	(150-175 Wp)	

All models listed above have 6" Multicrystalline cells.

Maximum System Voltage: 1000 VDC

Fire Classification: Type 2

Electrical ratings are provided at Standard Test Conditions (STC) 1000W/m<sup>2</sup>, AM1.5 spectrum, 25°C cell temperature.

Measured values at STC are within +/- 10% of ratings.

7

Appendix: 1, 1-11

**Licensed Test mark:**



**Date of Issue**

(day/mo/yr)

18/12/2015



TÜV Rheinland PTL

# Certificate

Certificate no.

US 82150004 03

**License Holder:**

Vikram Solar Pvt. Ltd.  
Tobacco House  
1 Old Court House Corner  
700001 Kolkata, West Bengal  
India

**Manufacturing Plant:**

Vikram Solar Pvt. Ltd.  
Falta Sez, Sector - II  
24 Parganas (S)  
743 504 West Bengal  
India

Test report no.: USA-BL 31540003 003

Client Reference: Manoranjan Khuntia

Tested to: UL 1703:2002 R5.14

**Certified Product:** Photovoltaic Module

**License Fee - Units**

**Model Designation:**

ELDORA VSP.72.AAA.03.04 or VSPB.72.AAA.03.04	(290-355 Wp)	7
ELDORA VSP.60.AAA.03.04 or VSPB.60.AAA.03.04	(245-295 Wp)	
ELDORA VSP.54.AAA.03.04 or VSPB.54.AAA.03.04	(220-265 Wp)	
ELDORA VSP.48.AAA.03.04 or VSPB.48.AAA.03.04	(195-240 Wp)	
ELDORA VSP.36.AAA.03.04 or VSPB.36.AAA.03.04	(145-180 Wp)	

All models listed above have 6" Multicrystalline cells.

Maximum System Voltage: 1000 VDC

Fire Classification: Type 1

Electrical ratings are provided at Standard Test Conditions (STC) 1000W/m<sup>2</sup>, AM1.5 spectrum, 25°C cell temperature.

Measured values at STC are within +/- 10% of ratings.

7

Appendix: 1, 1-13

**Licensed Test mark:**



**Date of Issue**

(day/mo/yr)

23/03/2017